

**PRODUCT**      **VW3700 Concealed Awning Window**

**TEST RESULTS**

|                                                                                        |                        |             |
|----------------------------------------------------------------------------------------|------------------------|-------------|
| Thermal Transmittance (BTU/hr-ft <sup>2</sup> -°F)                                     | <b>U-FACTOR</b>        | <b>0.56</b> |
| Condensation Resistance Factor Frame                                                   | <b>CRF<sub>F</sub></b> | <b>51</b>   |
| Condensation Resistance Factor Glass                                                   | <b>CRF<sub>G</sub></b> | <b>64</b>   |
| Unit Size : 59" x 23 5/8" (awning)                                                     |                        |             |
| Glass makeup: 1" IGU<br>1/4" SB60 #2 (e=0.035)<br>1/2" Argon, TGI spacer<br>1/4" Clear |                        |             |

**TEST LAB**

**Architectural Testing Inc.**  
**(ATI)**  
York, PA 17406

|               |                 |
|---------------|-----------------|
| Report Number | A4281.02-116-46 |
| Test Date     | 10/19/10        |
| Report Date   | 10/29/10        |

Reference above report for complete test specimen description and data.

*Tubelite Representative:*



(sign) 05/28/18 (date)

Tim Fookes - Vice President of Engineering (title)

**TEST METHODS**

**Thermal Performance:** AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.