

PRODUCT **400SS Series Curtainwall**
 2-1/2" x 7 1/2"

TEST RESULTS

Sound Transmission Class	STC	32
Outdoor – Indoor Transmission Class	OITC	27
Unit Size : 78-7/8" x 79" (glazed wall configuration)		
Glass makeup: 1" IGU 1/4" clear temp 1/2" air aluminum spacer 1/4" clear temp		

TEST LAB

**Riverbank Acoustical
 Laboratories (RAL)**
 Geneva IL 60134

Report Number	RAL-TL18-292
Test Date	5/4/2018
Report Date	5/4/2018

Reference above test report for complete test specimen description and data.

Tubelite Representative:



(sign) 6/8/18 (date)

Tim Fookes - Vice President of Engineering (title)

TEST METHODS

ASTM E90-09 (2016): Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413-16: Standard Classification for Rating Sound Insulation

ASTM E1332-16: Standard Classification for Rating Outdoor-Indoor Transmission Class