

PRODUCT **400T Series Curtainwall**
 2-1/2" x 7-3/4" (Thermal pressure plates)

TEST RESULTS

Condensation Resistance Factor Frame	CRF_F	80
Condensation Resistance Factor Glass	CRF_G	76
Thermal Transmittance (BTU/hr-ft ² -°F)	U-FACTOR	0.36
Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)		
Glass makeup: 1" IGU 1/4" Solar Ban 70XL #2 (e=0.018) 1/2" argon 90%, TriSeal Super Spacer 1/4" clear		

TEST LAB

UL CLEB
 Chicago, IL 60062

Report Number	NV-03079-2
Test Date	05/4/18
Report Date	8/2/18

Reference the above report for complete test specimen description and data.

Tubelite Representative:  (sign) 1/31/2019 (date)
Tim Fookes - Vice President of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.