

**PRODUCT**      **Phantom 5000 Series Zero Sightline Awning**  
 (SSG and flatback frames)

**TEST RESULTS**

INSTALL TYPE	GLASS MAKEUP	STC	OITC
flatback	1" IGU: ¼" Clear – ½" Air w/ Alum spacer – ¼" Clear	<b>33</b>	<b>26</b>
SSG	1" IGU: ¼" Clear – ½" Air w/ Alum spacer – ¼" Clear	<b>33</b>	<b>26</b>
SSG	1" IGU: ¼" Clear – ½" Argon w/ Alum spacer – ¼" Clear	<b>32</b>	<b>26</b>
Unit Size : 59.0" x 23.625" (awning configuration)			

**TEST LAB**

**INTERTEK – ATI**  
 York, PA 17406

Report Number	G4838.01-113-11
Test Date	12/02/16
Report Date	03/17/17

Reference ATI report #G4838.01-113-11, dated 03/17/17, for complete test specimen description and data.

Tubelite Representative:  (sign) 5/11/17 (date)  
 Tim Fookes - Director of Engineering (title)

**TEST METHODS**

**ASTM E90-09:** Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

**ASTM E413-10:** Standard Classification for Rating Sound Insulation

**ASTM E1332-10a:** Standard Classification for Rating Outdoor-Indoor Transmission Class