

PRODUCT **TerraPorte 7600 Terrace Door**
 Single In-Swing (Polyamide strut thermal barrier)

TEST RESULTS

Sound Transmission Class	STC	35
Outdoor – Indoor Transmission Class	OITC	30
Unit Size : 37.5" x 82.375" (single swinging door configuration)		
Glass makeup: 1" IGU ¼" clear ½" air aluminum spacer ¼" clear		

TEST LAB

INTERTEK – ATI
 York, PA 17406

Report Number	G4834.01-113-11
Test Date	02/06/17
Report Date	02/15/17

Reference ATI report #G4834.0-113-11, dated 02/15/17, for complete test specimen description and data.

Tubelite Representative:  (sign) 2/28/17 (date)

 Tim Fookes - Director of Engineering (title)

TEST METHODS

ASTM E90-09: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413-10: Standard Classification for Rating Sound Insulation

ASTM E1332-10a: Standard Classification for Rating Outdoor-Indoor Transmission Class