

PRODUCT **T34000 ForceFront Blast Series Storefront**
 2-1/2" x 5" (single thermal barrier)

TEST RESULTS

Condensation Resistance Factor Frame	CRF_F	59
Condensation Resistance Factor Glass	CRF_G	69
Thermal Transmittance (BTU/hr-ft ² -°F)	U-FACTOR	0.37
Unit Size : 78-3/4" x 78-34"® (glazed wall configuration)		
Glass makeup: 1-5/16" IGU ¼" PPG Solarban 70XL #2 (e=0.018) ½" 95% argon, Super Spacer Premium ¼" clear – 0.090 PVB – ¼" clear		

TEST LAB

ATI
 York, PA 17406

Report Number	D4605.02-116-46
Test Date	4/23/14
Report Date	6/19/14

Reference above report for complete test specimen description and data.

Tubelite Representative:  (sign) 9/23/2019 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.